



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Donna
Patton, Borough of

Project Pb and Cu
Description

Lab Sample No. 1605346-006
Client Sample ID #6 413-S
Matrix Drinking Water (Rep)
Date Received 05/20/16 12:11
Date Sampled 05/20/16 06:30
Date Reported 05/26/16 14:47

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
Metals Furnace 3113B									
Lead	SM 3113B	<0.005	0.005	0.00069	mg/L	DW	Not Required	05/25/16	

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
Metals ICP 200.7									
Copper	EPA 200.7	0.103	0.005	0.00091	mg/L	DW	Not Required	05/25/16	

Approved By Carlton R. McCracken, Jr.
Carlton R. McCracken, Jr. Chemist



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Donna
Patton, Borough of

Project Pb and Cu
Description

Lab Sample No. 1605346-007
Client Sample ID #7 401-S
Matrix Drinking Water (Rep)
Date Received 05/20/16 12:11
Date Sampled 05/20/16 07:15
Date Reported 05/26/16 14:47

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
Metals Furnace 3113B									
Lead	SM 3113B	<0.005	0.005	0.00069	mg/L	DW	Not Required	05/25/16	
Metals ICP 200.7									
Copper	EPA 200.7	0.034	0.005	0.00091	mg/L	DW	Not Required	05/25/16	

Approved By Carlton R. McCracken, Jr.
Carlton R. McCracken, Jr. Chemist



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Donna
Patton, Borough of

Project Pb and Cu
Description

Lab Sample No. 1605346-008
Client Sample ID #8 404-S
Matrix Drinking Water (Rep)
Date Received 05/20/16 12:11
Date Sampled 05/20/16 08:00
Date Reported 05/26/16 14:47

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
Metals Furnace 3113B									
Lead	SM 3113B	0.008	0.005	0.00069	mg/L	DW	Not Required	05/25/16	

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
Metals ICP 200.7									
Copper	EPA 200.7	0.026	0.005	0.00091	mg/L	DW	Not Required	05/25/16	

Approved By Carlton R. McCracken, Jr.
Carlton R. McCracken, Jr. Chemist



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Donna
Patton, Borough of

Project Pb and Cu
Description

Lab Sample No. 1605346-009
Client Sample ID #9 414-S
Matrix Drinking Water (Rep)
Date Received 05/20/16 12:11
Date Sampled 05/20/16 06:20
Date Reported 05/26/16 14:47

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qif.
Metals Furnace 3113B									
Lead	SM 3113B	0.005	0.005	0.00069	mg/L	DW	Not Required	05/25/16	
Metals ICP 200.7									
Copper	EPA 200.7	0.178	0.005	0.00091	mg/L	DW	Not Required	05/25/16	

Approved By Carlton R. McCracken, Jr.
Carlton R. McCracken, Jr. Chemist



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Donna
Patton, Borough of

Project Pb and Cu
Description

Lab Sample No. 1605346-010
Client Sample ID #10 415-S
Matrix Drinking Water (Rep)
Date Received 05/20/16 12:11
Date Sampled 05/20/16 07:00
Date Reported 05/26/16 14:47

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qif.
Metals Furnace 3113B									
Lead	SM 3113B	<0.005	0.005	0.00069	mg/L	DW	Not Required	05/25/16	

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qif.
Metals ICP 200.7									
Copper	EPA 200.7	0.198	0.005	0.00091	mg/L	DW	Not Required	05/25/16	

Approved By Carlton R. McCracken, Jr.
Carlton R. McCracken, Jr. Chemist