

Lead

Lead have action levels instead of MCLs. An action level is exceeded when the concentration in more than 10 percent of tap water samples collected during a monitoring period exceeds the action level.

The Lead Action Level is 0.015 mg/L

As you can see in the chart below Patton Borough Water Department meets these requirements and is in compliance with the 90th Percentile requirement.

Lead 90th Percentile Chart – September 2016

Sample	Test		Result	Units
1609029-010	Lead	20	0.061	mg/L
1609029-002	Lead	19	0.031	mg/L
1609029-018	Lead	18th Sample, 90th Percentile	0.008	mg/L
1609029-001	Lead	17	<0.005	mg/L
1609029-003	Lead	16	<0.005	mg/L
1609029-004	Lead	15	<0.005	mg/L
1609029-005	Lead	14	<0.005	mg/L
1609029-006	Lead	13	<0.005	mg/L
1609029-007	Lead	12	<0.005	mg/L
1609029-008	Lead	11	<0.005	mg/L
1609029-009	Lead	10	<0.005	mg/L
1609029-011	Lead	9	<0.005	mg/L
1609029-012	Lead	8	<0.005	mg/L

1609029-013	Lead	7	<0.005	mg/L
1609029-014	Lead	6	<0.005	mg/L
1609029-015	Lead	5	<0.005	mg/L
1609029-016	Lead	4	<0.005	mg/L
1609029-017	Lead	3	<0.005	mg/L
1609029-019	Lead	2	<0.005	mg/L
1609029-020	Lead	1	<0.005	mg/L

For More Information

You may contact Ken Trinkley, Water Manager at (814) 674-3653 or the DEP Cambria Office at (814) 472-1900. For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's website at: www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.