

CARDAN LABORATORIES, INC.
PO BOX 541
634 14TH STREET
NORTHERN CAMBRIA, PA 15714-0541
PH: 814-948-8650 FAX: 814-948-5893
Coal, Water, Gas, Rock, Dust, Mine Air, Etc.
DEP CERTIFICATION 11-139

03/09/2017

PATTON BORO
P.O. BOX 175
PATTON, PA 16668

LABORATORY NUMBER: 5565

SOURCE: ID 703

SAMPLED BY: KRT DATE SAMPLED: 03/08/2017 09:00
DATE REC'D.: 03/08/2017 11:30

BACTERIOLOGICAL EXAMINATION

DATE STARTED: 03/08/2017 13:25 ANALYST: SS
DATE ENDED.: 03/09/2017 13:25 ANALYST: SS

TOTAL COLIFORM - MEMBRANE FILTRATION

TOTAL COLIFORM (M-ENDO AT 35.0 DEGREES C. FOR 24 HRS)

VOLUME OF SAMPLE: 100 ML

TOTAL COLIFORM: ABSENCE
METHOD: SM9222B

THIS TEST HAS INDICATED THAT THIS WATER IS ACCEPTABLE.

No problems were encountered during analysis of this workorder,
except if noted in this report.