

CARDAN LABORATORIES, INC.
PO BOX 541
634 14TH STREET
NORTHERN CAMBRIA, PA 15714-0541
PH: 814-948-8650 FAX: 814-948-5893
Coal, Water, Gas, Rock, Dust, Mine Air, Etc.
DEP CERTIFICATION 11-139

03/24/2017

PATTON BORO
P.O. BOX 175
PATTON, PA 16668

LABORATORY NUMBER: 5587

SOURCE: 702

SAMPLED BY: KRT DATE SAMPLED: 03/22/2017 09:00
DATE REC'D...: 03/22/2017 11:50

B A C T E R I O L O G I C A L E X A M I N A T I O N

DATE STARTED: 03/22/2017 13:00 ANALYST: SS
DATE ENDED...: 03/23/2017 13:00 ANALYST: SS

TOTAL COLIFORM - MEMBRANE FILTRATION

TOTAL COLIFORM (M-ENDO AT 35.0 DEGREES C. FOR 24 HRS)

VOLUME OF SAMPLE: 100 ML

TOTAL COLIFORM: ABSENCE
METHOD: SM9222B

THIS TEST HAS INDICATED THAT THIS WATER IS ACCEPTABLE.

No problems were encountered during analysis of this workorder,
except if noted in this report.

CARDAN LABORATORIES, INC.

BY: Scott Semelberger